


# CANTON

*BUILDING & SAFETY SERVICES*

## **MOBILE FOOD TRUCK ANNUAL INSPECTION CHECKLIST**







### MOBILE FOOD TRUCK ANNUAL INSPECTION CHECKLIST

Food Truck Name:		Mobile #:
License #:		
Owner / Operator:		Email:
<b>GENERAL SAFETY</b>		✓
<b>1.</b>	Obtain "Temporary Use" Permit at: <a href="https://canton.onlama.com/">https://canton.onlama.com/</a> (Canton Unified Development Code).	
<b>2.</b>	Ensure there is no public seating within the mobile food truck (NFPA 1, 50.8.3.2).	
<b>3.</b>	Ensure that there is clearance of at least 10ft away from buildings, structures, vehicles, and any combustible materials (NFPA 96, 17.2).	
<b>4.</b>	Verify fire department vehicular access is provided for fire lane and access roads (NFPA 1, 18.2.4).	
<b>5.</b>	Ensure clearance is provided for the fire department to access fire hydrants and access fire department connections (NFPA 1, 13.1.4: NFPA 1, 13.1.5).	
<b>6.</b>	Check that appliances using combustible media are protected by an approved wet chemical suppression system (NFPA 96, 10.1.2).	
<b>7.</b>	Verify portable fire extinguishers have been selected and installed in kitchen cooking areas in accordance with NFPA 10 (NFPA 96, 10.9).	
<b>8.</b>	Where cooking appliances that use solid fuel, such as charcoal or wood, produce grease-laden vapors, ensure the appliances are protected by listed fire-extinguishing equipment (NFPA 96, 15.7.1).	
<b>9.</b>	Ensure that workers are trained in the following (NFPA 96, 17.10): * Proper use of portable fire extinguishers and extinguishing systems (NFPA 96, 17.10.1(1)). * Proper method of shutting off fuel sources (NFPA 96, 17.10.1(2)). * Proper procedure for notifying the local fire department (NFPA 96, 17.10.1(1)). * Proper procedure to perform a simple leak test on gas connections (NFPA 96, 17.10.1(5)).	
<b>FUEL &amp; POWER SOURCES</b>		
<b>10.</b>	Verify that fuel tanks are filled to the capacity needed for uninterrupted operation during normal operating hours (NFPA 1, 10.14.11.1 for carnivals only).	
<b>11.</b>	Ensure that refueling is conducted only during non-operating hours (NFPA 96, 17.8.3).	
<b>12.</b>	Check that any engine-driven source of power is separated from the public by barriers, such as physical guards, fencing, or enclosures (NFPA 96, 17.5.2.2).	
<b>13.</b>	Ensure that any engine-driven source of power is shut down prior to refueling from a portable container (NFPA 1, 10.15.4).	
<b>14.</b>	Check that surfaces of engine-driven source of power are cool to the touch prior to refueling from a portable container.	

<b>15.</b>	<p>Make sure that exhaust from engine-driven source of power complies with the following:</p> <ul style="list-style-type: none"> <li>* At least 12 ft in all directions from openings and air intakes (NFPA 96, 17.5.2.3(1)).</li> <li>* At least 12 ft from every means of egress (NFPA 96, B.13).</li> <li>* Directed away from all buildings (NFPA 96, 17.5.2.3(2)).</li> <li>* Directed away from all other cooking vehicles and operations (NFPA 96, 17.5.2.3(3)).</li> </ul>	
<b>16.</b>	Ensure that all electrical appliances, fixtures, equipment, and wiring complies with the NFPA 70® (NFPA 96, 17.8.1).	
	<b>PROPANE SYSTEM INTEGRITY</b>	
<b>17.</b>	Check that the main shutoff valve on all gas containers is readily accessible. (NFPA 58, 6.26.4.1(3)). Check tank re-qualification date; 5-12 years	
<b>18.</b>	Ensure that portable gas containers are in the upright position and secured to prevent tipping over (NFPA 58, 6.26.3.4).	
<b>19.</b>	Inspect gas systems prior to each use (NFPA 96, 17.7.2.3).	
<b>20.</b>	Perform leak testing on all new gas connections of the gas system (NFPA 58, 6.16; NFPA 58, 6.17).	
<b>21.</b>	Perform leak testing on all gas connections affected by replacement of an exchangeable container (NFPA 58, 6.16; NFPA 58, 6.17).	
<b>22.</b>	Document leak testing and make documentation available for review by the authorized code official (58, 6.26.5.1(M)).	
<b>23.</b>	Ensure that on gas system piping, a flexible connector is installed between the regulator outlet and the fixed piping system (NFPA 58, 6.26.5.1(B)).	
<b>24.</b>	Where a gas detection system is installed, ensure that it is tested monthly (NFPA 96, 17.7.2.2).	
	<b>OPERATIONAL SAFETY</b>	
<b>25.</b>	Do not leave cooking equipment unattended while it is still hot. (This is the leading cause of home structure fires and home fire injuries.)	
<b>26.</b>	Operate cooking equipment only when all windows, service hatches, and ventilation sources are fully opened (NFPA 96, 12.1.1).	
<b>27.</b>	Close gas supply piping valves and gas container valves when equipment is not in use. (NFPA 58, 6.26.8.3).	
<b>28.</b>	Keep cooking equipment, including the cooking ventilation system, clean by regularly removing grease (NFPA 96, 12.4).	
	<b>SOLID FUEL (WHERE WOOD, CHARCOAL OR OTHER SOLID FUEL IS USED)</b>	
<b>29.</b>	Fuel is not stored above any heat-producing appliance or vent (NFPA 96, 15.9.2.2).	
<b>30.</b>	Fuel is not stored closer than 3 ft to any cooking appliance (NFPA 96, 15.9.2.2).	
<b>31.</b>	Fuel is not stored near any combustible flammable liquids, ignition sources, chemicals, and food supplies and packaged goods (NFPA 96, 15.9.2.7).	

**SOLID FUEL (WHERE WOOD, CHARCOAL OR OTHER SOLID FUEL IS USED) CON'T**

<b>32.</b>	Fuel is not stored in the path of the ash removal or near removed ashes (NFPA 96, 15.9.2.4).	
<b>33.</b>	Ash, cinders, and other fire debris should be removed from the firebox at regular intervals and at least once a day (NFPA 96, 15.9.3.6.1).	
<b>34.</b>	Removed ashes, cinders, and other removed fire debris should be placed in a closed, metal container (NFPA 96, 15.9.3.8.1).	



## GAS CYLINDER REQUALIFICATION

RIN number identifying  
retester/requalifier

7<sup>A1</sup> 14

Month last  
requalified      Year last  
requalified



### Volumetric Test.

Basic Marking. Must be requalified within 12 years of stamped date (Must be requalified by 7/2026 in this example)





### Proof Pressure Test.

"S" indicates cylinder must be requalified within 7 years of stamped date (Must be requalified by 7/2021 in this example)



### External Visual Test.

"E" indicates cylinder must be requalified within 5 years of stamped date (Must be requalified by 7/2019 in this example)



**Food Truck Interior**

**Food Truck Exterior**

**Solid Fuel Use**

